

INDEPENDENT ASSESSMENT DECLARATION

For

**Omniflex PTY LTD
Durban, South Africa**

Of

Omni-16C Alarm Annunciator


The Failure Rate Calculations and associated Failure Modes, Effects and Diagnostics Analysis as produced by Omniflex PTY LTD have been reviewed.

On this basis the abovementioned product was assessed as suitable for use in safety related applications of Safety Integrity Level 1 in accordance with IEC 61508:2000.

Refer to report number 035001 Rev. 3 for details pertaining to SSF & PFD determination as well as conditions required for the usage of the device in safety related applications.

Declaration Number: 040401

Date of Issue: 19 January 2004



Owen Tavener-Smith, CFSE

